



03			
02			
01			
00			
Rev	Description	Date	APVD

Revision History

- Power Supply: 24V AC
- P.E: Protective Earth
  - H: Heater
  - HT: Heater Thermostat
  - MT: Motor Thermostat
  - M: Motor
  - LS1: Limit Switch for OPEN (5A/250V AC)
  - LS2: Limit Switch for CLOSE (5A/250V AC)
  - LS3: SPDT Auxiliary Limit Switch (5A/250V AC)
  - LS4: SPDT Auxiliary Limit Switch (5A/250V AC)
  - TS: Torque Switches (optional)

- Notes:
- 1) Modulating Board  
Input Signal : 4-20mA, 2-10V  
(It is suggested to use the shielding wire and its length should not exceed 30m.)  
Output Signal : 4-20mA, 2-10V
  - 2) Wiring is shown with Actuator Fully Closed.
  - 3) **Applicable to Actuator models iVQ-M, N.**

**ivact**  
*Innovative Actuation Incorporated*

1-215 Traders Blvd. Mississauga, Ontario Canada www.ivact.com

DESCRIPTION:  
24V AC Modulating with Heater, Thermostat,  
Auxiliary Switches and 4-20mA Feedback  
75% Duty

WIRING DIAGRAM CODE: QM DATE: JAN. 12/2021

WIRING DIAGRAM NO.: Q-1FN21N3N-3