



03			
02			
01			
00			
Rev	Description	Date	APVD

**Revision History**

Power Supply: 110-120V AC or 220-240V AC

- P.E: Protective Earth
- H: Heater
- HT: Heater Thermostat
- MT: Motor Thermostat
- M: Motor
- C: Capacitor
- LS1: Limit Switch for OPEN (5A/250V AC)
- LS2: Limit Switch for CLOSE (5A/250V AC)
- LS3: SPDT Auxiliary Limit Switch (5A/250V AC)
- LS4: SPDT Auxiliary Limit Switch (5A/250V AC)
- TS: Torque Switches (optional)

- Notes:
- 1) Modulating Board  
Input Signal : 4-20mA, 2-10V  
(It is suggested to use the shielding wire and its length should not exceed 30m.)  
Output Signal : 4-20mA, 2-10V
  - 2) Wiring is shown with Actuator Fully Closed.
  - 3) **Applicable to Actuator models iVQ-E to N.**

**ivact**  
*Innovative Actuation Incorporated*

1-215 Traders Blvd. Mississauga, Ontario Canada www.ivact.com

**DESCRIPTION:**  
110/220V AC Modulating with Heater,  
Thermostat, Auxiliary Switches and  
4-20mA Feedback 30% Duty

WIRING DIAGRAM CODE:	QT	DATE:	JAN. 08/2021
WIRING DIAGRAM NO.:	<b>Q-2BN21N3N-1</b>		