



03			
02			
01			
00			
Rev	Description	Date	APVD

Revision History

Power Supply: 220-240V AC

S1: Local/Remote Selector Switch
 S2: OPEN / OFF / CLOSE Selector Switch
 PE: Protective Earth
 H: Heater
 HT: Heater Thermostat
 MT: Motor Thermostat
 M: Motor
 LS1: Limit Switch for OPEN (5A/250V AC)
 LS2: Limit Switch for CLOSE (5A/250V AC)
 LS3: SPDT Auxiliary Limit Switch (5A/250V AC)
 LS4: SPDT Auxiliary Limit Switch (5A/250V AC)
 LR: Local Remote Contact (optional)
 RY1: Alarm Relay (optional)
 TS: Torque Switches (optional)

- Notes:
- 1) "N" connects to 5, "L" connects to 4.
 - 2) Select "Remote" Mode : Controlled by signal.
 - 3) Select "Local" Mode : Controlled by S2.
 - 4) Input Signal : 4-20mA, 2-10V.
 - 5) Output Signal : 4-20mA, 2-10V.
 - 6) Contacts 16 and 17 connect in "Remote" mode.
Contacts 16 and 18 connect in "Local" mode.
 - 7) Contacts 13 and 15 connect for power failure.
 - 8) Wiring is shown with Actuator Fully Closed.
 - 9) **Applicable to Actuator models iVQ-O to R.**

Innovative Actuation Incorporated
 1-215 Traders Blvd. Mississauga, Ontario Canada www.ivact.com

DESCRIPTION:
 220V AC Modulating with Heater, Thermostat,
 Auxiliary Switches, 4-20mA Feedback and
 Local Control Unit 50% Duty

WIRING DIAGRAM CODE: **QY** DATE: **APR. 21/2018**

WIRING DIAGRAM NO.: **Q-2DL21N3N-2**