



03			
02			
01			
00			
Rev	Description	Date	APVD

Revision History

Power Supply: 110-120V AC

P.E: Protective Earth
H: Heater
HT: Heater Thermostat
MT: Motor Thermostat
M: Motor
LS1: Limit Switch for OPEN (5A/250V AC)
LS2: Limit Switch for CLOSE (5A/250V AC)
LS3: SPDT Auxiliary Limit Switch (5A/250V AC)
LS4: SPDT Auxiliary Limit Switch (5A/250V AC)
TS: Torque Switches (optional)

- Notes:
- 1) Modulating Board
Input Signal : 4-20mA, 2-10V
(It is suggested to use the shielding wire and its length should not exceed 30m.)
Output Signal : 4-20mA, 2-10V
 - 2) Wiring is shown with Actuator Fully Closed.
 - 3) **Applicable to Actuator models iVQ-O to R.**


Innovative Actuation Incorporated
1-215 Traders Blvd. Mississauga, Ontario Canada www.ivact.com

DESCRIPTION:
110/220V AC Modulating with Heater,
Thermostat, Auxiliary Switches and
4-20mA Feedback 50% Duty

WIRING DIAGRAM CODE: **QZ** DATE: **JAN. 12/2021**

WIRING DIAGRAM NO.: **Q-2DN21N3N-1**